

Consumer Confidence Report Certification Form

Water System Name: **OWENS BROCKWAY**

Water System Number: **3900825**

The water system named above hereby certifies that its Consumer Confidence Report was distributed on JUNE 30 (date) to customers (and appropriate notices of availability have been given). Further, the system certifies that the information contained in the report is correct and consistent with the compliance monitoring data previously submitted to the Department of Public Health.

Certified By: Name STEVEN NOWIE

Signature 

Title ENVIRONMENTAL SPECIALIST

Phone Number (209) 836-8269 Date JUNE 25, 14

To summarize report delivery used and good-faith efforts taken, please complete the below by checking all items that apply and fill-in where appropriate:

☐ CCR was distributed by mail or other direct delivery methods. Specify other direct delivery method used: _____

☒ "Good faith" efforts were used to reach non-bill paying customers. Those efforts included the following methods:

☐ Posted the CCR on the internet at www. _____

☐ Mailed the CCR to postal patrons within the service area (attach zip codes used)

☐ Advertised the availability of the CCR in news media (attach copy of press release)

☐ Publication of the CCR in a local newspaper of general circulation (attach a copy of the published notice, including name of the newspaper and date published)

☒ Posted the CCR in public places (attach a list of locations)

☐ Delivery of multiple copies of CCR to single bill addresses serving several persons, such as apartments, businesses and schools

☐ Delivery to community organizations (attach a list of organizations)

☐ For systems serving at least 100,000 persons: Posted CCR on a publicly-accessible internet site at the following address: www. _____

☐ For privately-owned utilities: Delivered the CCR to the California Public Utilities Commission

2013 Consumer Confidence Report

Water System Name: **OWENS BROCKWAY**

Report Date: **June 2014**

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2013

Este informe contiene información muy importante sobre su agua beber. Tradúzcalo ó hable con alguien que lo entienda bien.

Type of water sources(s) in use: This info is not available, as this water system does not have a completed assessment on file. Please see the Drinking Water Source Assessment Information section located at the end of this report for more details.

Your water comes from 1 source: WELL 02.

For more information about this report, or for any questions relating to your drinking water, please call (209) 838 - 7842 and ask for Quality Service, Inc..

TERMS USED IN THIS REPORT:

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency.

Public Health Goal (PHG): The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Primary Drinking Water Standards (PDWS): MCLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

Secondary Drinking Water Standards (SDWS): MCLs for contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

Regulatory Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Variances and Exemptions: Department permission to exceed an MCL or not comply with a treatment technique under certain conditions.

ND: not detectable at testing limit

ppm: parts per million or milligrams per liter (mg/L)

ppb: parts per billion or micrograms per liter (µg/L)

umhos/cm: micromhos per centimeter (a measure of conductivity)

TON: threshold odor numbers (a measure of odor)

pCi/l: picocuries per liter (a measure of radioactivity)

The sources of drinking water(both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, spring, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

2013 Consumer Confidence Report

Contaminants that may be present in source water include:

- *Microbial contaminants*, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.
- *Inorganic contaminants*, such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.
- *Pesticides and herbicides*, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Radioactive contaminants*, which can be naturally occurring or the result of oil production and mining activities.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, which are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.

In order to ensure that tap water is safe to drink, the U.S. Environmental Protection Agency (USEPA) and the California Department of Public Health prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. Department regulations also establish limits for contaminants in bottled water that must provide the same protection for public health.

Tables 1,2 and 3 list all of the drinking water contaminants that were detected during the most recent sampling for the constituents. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The Department allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old.

TABLE 1 - SAMPLING RESULTS SHOWING THE DETECTION OF LEAD AND COPPER						
Lead and Copper (complete if lead or copper detected in the last sample set)	No. of Samples Collected	90th Percentile Level	No. Site Exceeding AL	AL	PHG	Typical Sources of Contaminant
Lead (ppb)	4 (2012)	1.60	0	15	0.2	Internal corrosion of household water plumbing systems; discharges from industrial manufacturers, erosion of natural deposits
Copper (ppm)	4 (2012)	0.208	0	1.3	.3	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

TABLE 2 - DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD						
Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL (MRDL)	PHG (MCLG) [MRDLG]	Typical Sources of Contaminant
Chromium (ppb)	(2011)	16	20 - 20	50.0	n/a	Discharge from steel and pulp mills and chrome plating; erosion of natural deposits
Nitrate (ppm)	(2013)	33.8	34 - 34	45	45	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits

2013 Consumer Confidence Report

Selenium (ppb)	(2011)	9.0	9 - 9	50	30	Discharge from petroleum, glass, and metal refineries; erosion of natural deposits; discharge from mines and chemical manufacturers; runoff from livestock lots(feed additive)
----------------	--------	-----	-------	----	----	--

Any violation of MCL,AL or MRDL is shaded. Additional information regarding the violation is provided later in this report.

TABLE 3 - DETECTION OF UNREGULATED CONTAMINANTS					
Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	Notification Level	Health Effects Language
Vanadium (ppm)	(2011)	0.003	0.003 - 0.003	0.05	The babies of some pregnant women who drink water containing vanadium in excess of the action level may have an increased risk of developmental effects, based on studies in laboratory animals.
Chromium (Total) (ppb)	(2011)	16	20 - 20	n/a	n/a

Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care provider. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791)

For Lead (Pb), If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. *OWENS BROCKWAY* is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Summary Information for Contaminants Exceeding an MCL, MRDL, or AL, or a violation of Any Treatment Technique or Monitoring and Reporting Requirement

About our Nitrate: Nitrate in drinking water at level above 45 mg/L is a health risk for infants of less than six months of age. Such nitrate levels in drinking water can interfere with the capacity of the infant's blood to carry oxygen, resulting in a serious illness; symptoms include shortness of breath and blueness of the skin. Nitrate levels above 45 mg/L may also affect the ability of the blood to carry oxygen in other individuals, such as pregnant women and those with certain specific enzyme deficiencies. If you are caring for an infant, or you are pregnant, you should ask advice from your health care provider.

2013 Consumer Confidence Report

Drinking Water Source Assessment Information

Assessment Info

According to the Drinking Water Source Assessment and Protection Program's Source Water Assessments Public Access web page, the Public Water Sources WELL 02 of the OWENS BROCKWAY water system number 3900825, does not have a completed Source Water Assessment on file.

Discussion of Vulnerability

Assessment summaries are not available for some sources. This is because:

- The Assessment has not been completed. Contact the local Department of Health Services (DHS) Drinking Water field office or the water system to find out when the Assessment is scheduled to be done.
- The source is not active. It may be out of service, or new and not yet in service.
- The Assessment was not submitted electronically. The site used to obtain Assessments only provides access to Assessment summaries submitted electronically.

Acquiring Info

For more info you may visit <http://swap.ice.ucdavis.edu/TSinfo/TSintro.asp> or contact the health department in the county to which the water system belongs.

OWENS BROCKWAY

Analytical Results By FGL - 2013

LEAD AND COPPER RULE									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	90th Percentile	# Samples
Lead									
H & S Office	STK1237374-002	ppb	0	15	0.2	07/31/2012	1.70	1.60	4
H & S Restroom	STK1237374-001	ppb				07/31/2012	1.50		
Main Office Men	STK1237374-005	ppb				07/31/2012	0.900		
Main Office Wom	STK1237374-003	ppb				07/31/2012	1.50		
Copper									
H & S Office	STK1237374-002	ppm		1.3	.3	07/31/2012	0.0850	0.208	4
H & S Restroom	STK1237374-001	ppm				07/31/2012	0.212		
Main Office Men	STK1237374-005	ppm				07/31/2012	0.0900		
Main Office Wom	STK1237374-003	ppm				07/31/2012	0.204		

PRIMARY DRINKING WATER STANDARDS (PDWS)									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Chromium									
WELL 02	STK1139042-001	ppb	100	50.0		10/11/2011	16.0	16	20 - 20
Nitrate									
WELL 02	STK1350279-001	ppm		45	45	10/15/2013	33.8	33.8	34 - 34
Selenium									
WELL 02	STK1139042-001	ppb	50	50	30	10/11/2011	9.00	9.0	9 - 9

UNREGULATED CONTAMINANTS									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Chromium (Total)									
WELL 02	STK1139042-001	ppb		NS		10/11/2011	16.0	16	20 - 20
Vanadium									
WELL 02	STK1139042-001	ppm		NS		10/11/2011	0.00300	0.003	0.003 - 0.003

OWENS BROCKWAY

CCR Login Linkage - 2013

FGL CODE	DATE SAMPLED	LAB ID	METHOD	DESCRIPTION	PROPERTY
BATCH FURNACE R	01/15/2013	STK1330492-001	Coliform	Batch & Furnace RR	Drinking Water Monitoring
	02/12/2013	STK1331213-001	Coliform	Batch & Furnace RR	Drinking Water Monitoring
	03/19/2013	STK1332498-001	Coliform	Batch & Furnace RR	Drinking Water Monitoring
	04/09/2013	STK1333257-001	Coliform	Batch & Furnace RR	Drinking Water Monitoring
	05/14/2013	STK1334645-001	Coliform	Batch & Furnace RR	Drinking Water Monitoring
	06/11/2013	STK1335748-001	Coliform	Batch & Furnace RR	Drinking Water Monitoring
	07/09/2013	STK1336841-001	Coliform	Batch & Furnace RR	Drinking Water Monitoring
	08/27/2013	STK1338601-001	Coliform	Batch & Furnace RR	Drinking Water Monitoring
	09/24/2013	STK1339504-001	Coliform	Batch & Furnace RR	Drinking Water Monitoring
	10/15/2013	STK1350282-001	Coliform	Batch & Furnace RR	Drinking Water Monitoring
	11/19/2013	STK1351344-001	Coliform	Batch & Furnace RR	Drinking Water Monitoring
	12/03/2013	STK1351731-001	Coliform	Batch & Furnace RR	Drinking Water Monitoring
H & S Office	07/31/2012	STK1237374-002	Metals, Total	H & S Office	Lead & Copper Monitoring
H & S Restroom	07/31/2012	STK1237374-001	Metals, Total	H & S Restroom	Lead & Copper Monitoring
Main Office Men	07/31/2012	STK1237374-004	Metals, Total	Main Office Mens Restroom (R)	Lead & Copper Monitoring
	07/31/2012	STK1237374-005	Metals, Total	Main Office Mens Restroom (L)	Lead & Copper Monitoring
Main Office Wom	07/31/2012	STK1237374-003	Metals, Total	Main Office Womens Restroom	Lead & Copper Monitoring
NEW LINE	12/02/2013	STK1351643-001	Coliform	New Line	Owens Brockway
SS of Gaugin	01/15/2013	STK1330492-002	Coliform	HB Southside of Gauging Dept.	Drinking Water Monitoring
	02/12/2013	STK1331213-002	Coliform	HB Southside of Gauging Dept.	Drinking Water Monitoring
	03/19/2013	STK1332498-002	Coliform	HB Southside of Gauging Dept.	Drinking Water Monitoring
	04/09/2013	STK1333257-002	Coliform	HB Southside of Gauging Dept.	Drinking Water Monitoring
	05/14/2013	STK1334645-002	Coliform	HB Southside of Gauging Dept.	Drinking Water Monitoring
	06/11/2013	STK1335748-002	Coliform	HB Southside of Gauging Dept.	Drinking Water Monitoring
	07/09/2013	STK1336841-002	Coliform	HB Southside of Gauging Dept.	Drinking Water Monitoring
	08/27/2013	STK1338601-002	Coliform	HB Southside of Gauging Dept.	Drinking Water Monitoring
	09/24/2013	STK1339504-002	Coliform	HB Southside of Gauging Dept.	Drinking Water Monitoring
	10/15/2013	STK1350282-002	Coliform	HB Southside of Gauging Dept.	Drinking Water Monitoring
	11/19/2013	STK1351344-002	Coliform	HB Southside of Gauging Dept.	Drinking Water Monitoring
	12/03/2013	STK1351731-002	Coliform	HB Southside of Gauging Dept.	Drinking Water Monitoring
WELL 02	10/11/2011	STK1139042-001	Metals, Total	WELL #2	Water Quality Monitoring
	10/15/2013	STK1350279-001	Wet Chemistry	WELL #2	Water Quality Monitoring